



SECTION [08 44 29] [08973] [10 5020] Glass Canopies

Vision Series Glass Canopies

MASA Architectural Canopies
21 Randolph Ave.
Avenel, NJ 07001
P. 732-453-6120
F. 732-453-6126
Architecturalcanopies.com

Vision Series Glass Canopy System

General Notes to Architect

***** Unique, custom designed, glass canopies (Vision Series), extruded aluminum and steel structures including hanger rod suspended canopies (Extrudeck series), post mounted canopies, Pre-engineered canopy systems, sunshade and louver products (Ecoshade series) and other structures can add distinction, exceptional beauty, and expansive visibility to a construction project. However, these structures require meticulous engineering, extensive knowledge of materials and codes, broad experience, quality materials, and expert craftsmanship. Each design will have unique parameters and requirements which must be accurately addressed in order to provide a safe, functional, durable, weather-resistant structure which can withstand wind, seismic loads, thermal expansion and contraction. It is critical that unique glass structures be both designed and fabricated by a single, knowledgeable entity assuming complete responsibility. Piece-meal assembly of products from numerous manufacturers and fabricators without a comprehensive design and engineered solution is not a method for achieving a functional and safe structure.

MASA Architectural Canopies, Inc. can provide this essential sole source design, fabrication and installation responsibility. They are a domestic company focused on the United States market. They provide glass luxury at affordable prices in a timely manner. MASA Architectural Canopies, Inc. designs and fabricates a wide variety of glass, extruded aluminum and steel structures including hanger rod suspended canopies, post mounted canopies, pre-engineered canopy systems, sunshade and louver products

This specification guide can be used to specify a custom designed and engineered exterior glass canopy.

In contrast to more typical descriptive specifications, this section is a performance type emphasizing the critical factor of design and engineering. It provides a convenient format that can be edited to reflect the unique glass structure envisioned by an architect and ensure that it is correctly engineered, carefully detailed, accurately fabricated, and properly installed.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies



This specification section is organized by placing information in three standard parts:

- PART 1 - GENERAL Describes the design and performance criteria for the glass canopy and other administrative and procedural requirements.
- PART 2 - PRODUCTS Describes materials, products, accessories, and fabrication methods to be used for the glass canopy.
- PART 3 - EXECUTION Describes how the components will be assembled and installed at the construction site.

Throughout this product guide specification, references are made to other specification sections that might be contained in the project manual. These references are presented as examples and coordination reminders. For each project, these references will need to be revised to reflect actual sections being used.

The six-digit specification section numbers in this guide are based on classifications and numbers contained the 2004 Edition of MasterFormat published by the Construction Specifications Institute (CSI) and Construction Specifications Canada (CSC). This is the industry standard for organizing construction specifications. Previous five-digit numbers from the 1995 Edition of MasterFormat have also been included in this guide and are listed in brackets following the 2004 Edition numbers.

Within the specification text, Imperial dimensions are presented first in brackets followed by System International Metric (SI) equivalents also in brackets. Depending on project requirements, either the Imperial or the SI metric equivalents will need to be deleted.

The specifier will need to edit this product specification for a specific project to reflect the options and applications being used. The guide section has been written so that much editing can be accomplished by deleting unnecessary requirements and options. Additional information describing the desired characteristics of the glass structure will need to be added by the specifier. Options are indicated by []. Notes to assist the specifier in selecting options and editing the specification guide are printed in bold and indicated with *****. For final editing, all brackets and notes will need to be deleted from the guide.



PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes: Functional design, structural engineering, custom fabrication, and site erection of glass canopy for [type of project or structure].

***** List other specification sections dealing with work directly related to this section such as the following. *****

B. Related sections:

1. Section [03 30 00] [03300] - Cast-in-Place Concrete: Concrete framing to support canopy.
2. Section [04 05 10] [04800] - Masonry Assemblies: Masonry framing to support canopy.
3. Section [05 12 00] [05120] - Structural Steel: Steel framing to support canopy.

***** Glass for canopy may be specified in this section or in a separate section covering glass for all project glazing. However, supply and installation of glass must be part of this section to ensure sole source responsibility. Include the following paragraph if glass is specified in a separate section. *****

4. Section [08 80 00] [08800] - Glazing: Glass to be supplied and installed as part of this Section.

1.2 REFERENCES

***** List by number and full title reference standards referred to in remainder of specification section. Delete non-applicable references. *****

- A. American National Standards Institute (ANSI): ANSI Z97.1 - Safety Performance Specifications and Methods of Test for Safety Glazing Material Used in Buildings.
- B. American Society of Civil Engineers (ASCE): ASCE 7 - Minimum Design Loads for Buildings and Other Structures.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

3



C. American Society for Testing and Materials (ASTM):

1. ASTM A167 - Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip.
2. ASTM A269 - Seamless and Welded Austenitic Stainless Steel Tubing for General Service.
3. ASTM A276 - Stainless and Heat-Resisting Steel Bars and Shapes.
4. ASTM A653 - Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by Hot-Dip Process.
5. ASTM B248 - Wrought Copper and Copper Alloy Plate, Sheet, Strip, and Rolled Bar.
6. ASTM B221 - Aluminum-Alloy Extruded Bar, rod, Wire, Shape, and Tube.
7. ASTM C509 - Elastomeric Cellular Preformed Gasket and Sealing Material.
8. ASTM C864 - Dense Elastomeric Compression Seal Gaskets, Setting Blocks, and Spacers.
9. ASTM C920 - Elastomeric Joint Sealants.
10. ASTM C1036 - Flat Glass.
11. ASTM C1048 - Heat Treated Flat Glass, Kind HS, Kind FT, Coated and uncoated.
12. ASTM C1115 - Dense Elastomeric Silicone Rubber Gaskets and Accessories.
13. ASTM C1172 - Laminated Architectural Flat Glass.
14. ASTM C1281 - Preformed Tape Sealants for Glazing Applications.
15. ASTM E330 - Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference.
16. ASTM E331 - Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference.
17. ASTM E1300 - Determining Load Resistance of Glass in Buildings.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

4



- D. Consumer Product Safety Commission (CPSC): CPSC 16 CFR 1201 - Safety Standard for Architectural Glazing Materials.
- E. Glass Association of North America (GANA): GANA - Glazing Manual.
- F. International Code Council (ICC): ICC IBC - International Building Code.

1.3 GLASS CANOPY DESCRIPTION

- A. Exterior glass canopy to be custom designed, engineered, detailed, factory fabricated, and site assembled and erected.

***** Unique glass canopies can be created by MASA Architectural Canopies,, Inc. Contact them for available options and assistance in planning and specifying. Edit the following paragraph to reflect basic configuration of canopy. *****

- B. Basic configuration: [Flat] [Single sloped] [Double pitched] [Vaulted] [Dome] [_____] shape to provide architectural appearance shown on Drawings.
- C. Dimensions: Glass canopy shall be nominal dimensions shown on Drawings. Minor variations to accommodate manufacturer's design and components are acceptable provided overall concept is maintained.

***** Numerous methods of glazing and structural support can be used to accomplish the unique appearance and style desired by the architect and owner. Consult with MASA Architectural Canopies, Inc. on available methods and their characteristics, features, cost, and limitations. Selection of method can be defined by design professional in consultation with MASA Architectural Canopies,, Inc. or determination of system can be delegated to manufacturer. *****

- D. Type of glass canopy: [Metal framing with glass panels.] *** [Metal support framing with contact structural silicone sealant glazing.] *** [Glass panels supported by glass fin joists with metal connector fittings.] *** [Glass panels supported by tension truss joists with metal connector fittings.] *** [Glass panels supported by laminated glass joists and structural silicone sealant joints.] *** [As determined by manufacturer to efficiently provide configuration and size of glass canopy shown on Drawings.] *** [other method as determined in consultation with MASA Architectural Canopies, Inc.]

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

5



1.4 DESIGN AND PERFORMANCE CRITERIA

***** MASA Architectural Canopies, Inc. will provide structural engineering and design for support system, connections, anchors, seals, and other elements of glass canopy. Edit this article to reflect project conditions and applicable codes. *****

A. Design Requirements:

1. Design Wind Load: [_____] pounds/square foot] [_____] kilograms/square meter]
2. Snow Load (if applicable): [_____] pounds/square foot] [_____] kilograms/square meter]
3. Seismic Zone: [_____]]
4. Live load deflection of supporting structure (if any): [_____]]

B. Design, size components, and install glass canopy in accordance with ASTM E1300 to withstand these loads without breakage, loss, failure of seals, product deterioration, and other defects.

1. Dead and live loads: Determined by ASCE 7 and calculated in accordance with applicable codes.
2. Seismic loads: System shall be designed and installed to comply with applicable seismic requirements for Project location and Seismic Zone [0] [1] [2A] [2B] [3] [4] as defined by of ICC/IBC.
3. Movement and deflection of structural support framing.
4. Effects of applicable wind load acting inward and outward normal to plane of canopy in accordance with ASTM E330.
5. Thermal loads and movement:
 - a. Ambient temperature range: [[120] [_____] degrees F.] [[48] [_____] degrees C.]
 - b. Material surfaces range: [[180] [_____] degrees F.] [[82] [_____] degrees C.]

SECTION [08 44 29] [08973] [10 5020] Glass Canopies



- B. Provide and install exterior gaskets, sealants, and other glazing accessories to resist water penetration. There shall be no penetration at [15] [_____] pounds/square foot] [[73] [_____] kilograms/square meter] test pressure and [[5] [_____] gallons/hour/square foot] [[18] [_____] liters/hour/square meter] water rate tested in accordance ASTM E331.

1.5 SUBMITTALS

- A. Submit in accordance with Section [01 33 00] [01330] - Submittal Procedures:

1. Product data for all proposed components, materials, products, and accessories.
 - a. For each type glass, provide maximum allowable stress in both horizontal and vertical directions.
 - b. Provide photographs or drawings for fittings and hardware.
2. Shop drawings:
 - a. Plans, elevations, and sections illustrating shape, configuration, and dimensions. For complex canopies provide perspectives, renderings, or models.
 - b. Illustrate method of assembly, installation, and glazing.
 - c. Provide details for support framing, reinforcement, connections, joints, anchors, and other fabrication and installation conditions.
 - d. Indicate required tolerances and coordination with adjacent elements and work of other trades.
3. Calculations: Show compliance with performance criteria and applicable loads with stamp of Licensed Professional Engineer registered in the State of [_____].



4. Samples:

***** Edit the following list to reflect components required for glass canopy. *****

- a. [12 by 12 inches] [152 by 152 mm] minimum size for each type glass.
 - b. [6 inches] [152 mm] minimum length of metal support framing.
 - c. [6 inches] [152 mm] minimum length for [structural silicone sealant] [butt] [resilient gasket] [_____] glazed joint.
 - d. Metal finishes.
 - e. Sealant colors.
5. Manufacturer's installation and maintenance instructions.
 6. Certificates or test reports demonstrating components and methods have been successfully tested by an independent laboratory in the United States certifying that the proposed system has been tested and as defined by Paragraph [1.4] [_____].
 7. Data showing compliance with manufacturer's and installer's qualifications specified in Paragraphs [1.6.A and 1.6.B] [_____]. Provide descriptions, locations, photographs, references, and completion dates for previous projects.
 8. Copies of warranties required by Paragraph [1.11] [_____] for review by Architect. Included with warranty shall be a letter certifying the proposed system will be manufactured from one source. Glass cannot be supplied by one manufacturer and hardware from another manufacturer to comply with this warranty. Letters signed by the subcontractors or installers for this section are not acceptable.

1.6 QUALITY ASSURANCE

***** To ensure that completed glass canopy is structurally sound, weather tight, functional, durable, and safe; specify that design, engineering, fabrication, and supply of all components, materials, and products be the sole responsibility of an experienced single entity such as MASA Architectural Canopies, Inc. It is critical that unique glass structures be both designed and fabricated by a single, knowledgeable entity assuming complete responsibility. Piece-meal assemblies of products from numerous manufacturers and fabricators without a comprehensive design and engineered solution is not a method for achieving a functional, safe, glass structure.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies



- A. Single source responsibility: Design, structural engineering, and custom fabrication for glass canopy and supply of all components, materials, and products shall be sole responsibility of single manufacturer. Provision of products from numerous sources for site assembly without complete single source design and supply responsibility is not acceptable. Components to be fabricated or supplied by single source are:

***** Edit the following list to reflect components required for glass canopy. *****

1. Support framing.
 2. Glass [as specified in Section [08 80 00] [08800] - Glazing].
 3. Connectors, fittings, anchors, and installation accessories.
 4. Gaskets, glazing tape, and sealants.
 5. All other components, products, and materials required for complete, functional glass canopy.
- B. Single installation responsibility: All components listed in Paragraph [1.6.A] [_____] shall be installed by a single installer.
- C. Manufacturer qualifications: Company specializing in designing, engineering, and fabricating unique, custom designed, glass canopies, facades, entrances, storefronts, and other glazed structures. Glass cannot be supplied by one manufacturer and hardware from another manufacturer to comply with this warranty. Letters signed by the subcontractors or installers for this section are not acceptable.
1. Experience: 7 years minimum successful experience providing glass structures.
 2. Previous projects: Successfully completed 10 minimum glass structures of scope, type, and size as proposed Project.
- D. Installer qualifications: Company experienced in erecting custom designed, glass canopies, facades, entrances, storefronts, and other glazed structures and acceptable to manufacturer for installing proposed structure.
1. Experience: 3 years minimum successful experience erecting glass structures.
 2. Previous projects: Successfully completed 3 minimum glass structures of scope, type, and size as proposed Project.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

9



- E. Design structural components and develop shop drawings under direct supervision of professional structural engineer experienced in design of glass structures. Calculations and shop drawings shall bear engineer's seal.
- F. Safety glazing: Comply with Consumer Product Safety Commission 16 CFR 1201, ANSI Z97.1, and other applicable safety requirements. Each piece of safety glazing shall be permanently labeled with appropriate marking.

***** For large, more complicated canopies it is appropriate that MASA Architectural Canopies, Inc. send a field representative to oversee installation. Use the following paragraph to require manufacturer's field representative. *****

- G. Manufacturer's field representative:
 - 1. During installation, provide services of manufacturer's field representative knowledgeable of erection process for proposed glass canopy.
 - 2. Manufacturer's representative shall observe installation, quality control, and certify work meets specified requirements.
 - 3. Manufacturer's representative shall submit report covering observations, procedures, noted deficiencies, corrective measures, and certification of proper installation.

1.7 MOCK-UP

***** For larger projects or complicated conditions a mock-up may be important to establish work-ability and performance of proposed canopy. Include this article to request mock-up constructed on site separate from actual construction. *****

- A. In accordance with Section [01 40 00] [01400] - Quality Control, prepare separate mock-up illustrating construction method for glass canopy. Mock-up shall demonstrate performance and establish workmanship quality standard.
- B. Provide posts and other framing to support canopy mock-up to allow inspection from above and below canopy.
- C. Mock-up shall be portion of canopy with glass panels, support framing, curb, flashing, and fittings. Construct with all anchors, fasteners, sealants, and other components proposed for actual installation.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

10



- D. Approximate size: [6 by 6 feet] [2 by 2 m] [_____].
- E. Test mock-up with [water hose to verify weather tightness] [[other test] to verify [type of performance].
- F. Submit report describing tests, results, and any modifications made to correct deficiencies or to improve performance.
- G. Do not proceed with installation until mock-up has been inspected and accepted by Architect.
- H. Retain approved mock-up during construction as quality standard. Completely remove when work is accepted.

1.8 PRE-INSTALLATION CONFERENCE

***** Depending on project size, complexity of glass canopy, and number of coordination items, a pre-installation conference maybe important. Include this article to specify pre-installation conference. *****

- A. In accordance with Section [01 31 00] [01310] - Project Management and Coordination, convene a pre-installation conference at site prior to commencing work of this Section.
- B. Require attendance of entities directly concerned with canopy [including manufacturer's field representative].
- C. Review at meeting:

***** Add to and edit the following list to reflect project conditions. *****

1. Coordination with supports, wall system, and preparation for attachment of canopy.
2. Schedule, sequence, and method for installing glass canopy and coordination with other work.
3. Safety procedures.
4. Availability of system materials.
5. Chemical compatibility of metal framing, glass panels, sealants, and other glazing materials.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

11



6. Protection of adjacent items and finishes.
7. Approved mock-up to be used a measure of acceptance.
8. Other items related to successful execution of work.

1.9 PRODUCT HANDLING

- A. Protect glass and other components during delivery, storage, and handling in accordance with manufacturer's instructions. Prevent edging chipping and other damage.
- B. Do not store glass panels on site for extended time.

1.10 ENVIRONMENTAL REQUIREMENTS

- A. During glazing, maintain [40 degrees F] [4 degrees C] minimum temperature.

1.11 WARRANTIES

- A. Provide under provisions of Section [01 77 00] [01770] - Closeout Procedures:
 1. Manufacturer's 2 years warranty to cover design, fabrication, and materials against defects and failure to perform and remain watertight. Warranty to provide for replacement of defective components.
 2. Glass warranties: 5 years warranty to cover replacement of laminated glass units in event of de-lamination, edge separation, and blemishes.
 3. Installer's 5 years warranty to cover installation against defects and failure to perform and remain watertight. Warranty to provide for required repairs.



PART 2 - PRODUCTS

2.1 ACCEPTABLE DESIGNER-MANUFACTURER

- A. Glass canopy shall be designed and fabricated by MASA Architectural Canopies, Inc.

VISION SERIES GLASS CANOPY

1. Address: 21 Randolph Ave. Avenel N.J. 07001
 2. Phone: 732-453-6120 Fax: 732-453-6126
 3. Website: www.architecturalcanopies.com
- B. Requests to use design services and products of another manufacturer must be submitted in accordance with Section [01 63 00] [01630] - Product Substitution Procedures.

2.2 GLASS

***** MASA Architectural Canopies, Inc. typically fabricates exterior glass canopies from monolithic laminated glass. Insulating glass is not required for exterior conditions. Laminated glass is fabricated by bonding two or more glass panes with a transparent, flexible interlayer material. Laminated glass qualifies as safety glass. When broken, laminated glass tends to remain in place with glass particles adhered to interlayer. It is acceptable by most codes for use in canopies.

Fully tempered glass also qualifies as safety glass and is acceptable by most codes for use in canopies. It tends to break into small cubical pieces. However, tempered glass used as single glass layer in canopies requires a screen be installed below it. For aesthetics, monolithic tempered glass is not recommended for canopies.

As previously noted, glass products can be specified in this section or in Section 08 80 00 (08800) - Glazing with a reference in this section. If glass is specified in this section, include the following paragraph to specify monolithic, laminated glass for use in canopy. *****

- A. Type of glass: [As specified in Section [08 80 00] [08800] - Glazing.] [Laminated glass fabricated by bonding two or more glass panes with transparent, flexible interlayer material in accordance with ASTM C1172. Laminated glass shall meet requirements of ANSI Z97.1 and CPSC 16 CFR to qualify as safety glass.]

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

13



***** Laminated glass panels can be fabricated with either annealed, heat strengthened, or fully tempered glass. Heat strengthened glass is approximately twice as strong as annealed glass of equal thickness. Fully tempered glass is approximately four times as strong as annealed glass of equal thickness. *****

- B. Fabricate laminated glass for canopy components from either ASTM C1036 annealed, ASTM C1048 Kind HS heat strengthened, or ASTM C1048 Kind FT fully tempered glass as determined by manufacturer to accommodate Project design and performance requirements specified in Paragraph [1.4] [_____].

***** Edit the following paragraph to reflect if clear, color tinted, reflective coated, or low-E glass is required. *****

- C. Color: [Clear] [Blue] [Light green] [Dark green] [Light gray] [Medium gray] [Dark gray] [Bronze] [_____].

***** Include the following paragraph if reflective coated glass is required. *****

- D. Provide laminated glass with reflective metallic oxide coating deposited during production.

***** Include the following paragraph if low-E glass is required. *****

- E. Provide laminated glass with low emissivity (low-E) neutral coating pyrolytically applied to improve thermal performance and reduce solar heat gain.
- F. Glass thickness: Determined by glass canopy manufacturer to accommodate Project design and performance requirements specified in Paragraph [1.4] [_____].

***** Glass canopy panels can be mechanically installed with stainless steel connectors and fittings. These devices require accurately drilled holes in glass to receive fitting pins and bolts. Holes must be drilled prior to tempering glass panels. Include this paragraph if mechanically installed glass panels are required. *****

- G. For glass panels to be installed with mechanical connectors and fittings, provide holes to receive bolts and fitting pins. Holes shall be drilled prior to tempering glass.



2.3 METAL SUPPORT FRAMING

***** Glass canopies can be supported and framed with metal framing such as aluminum, steel, stainless steel, and bronze. Material selection can be made by design professional in conjunction with MASA Architectural Canopies, Inc. or determination can be delegated to manufacturer. Resilient gaskets are typically used for glazing. This article can be used as a format to be edited and completed to specify metal support framing. Contact MASA Architectural Canopies, Inc. for assistance in planning, designing, selecting options, and detailing custom metal support framing. *****

- A. Framing sections: Provide metal framing to support glass canopy panels as detailed on Drawings and approved shop drawings.

***** Tubular or solid sections and either cold-formed, extruded, and hot-rolled members can be used as framing. Various finishes are also available. Edit the following paragraph to indicated type of metal support framing. *****

- B. Material: [Cold-formed from low carbon, hot dipped galvanized steel complying with ASTM A653 and finished with [electrostatically applied powder paint coating] [____].] *** [Cold-formed from stainless steel complying with ASTM A167 Type 304 with [brushed satin finish] [reflective polished finish] [____].] *** [Cold-formed from bronze alloy sheet complying with ASTM B248 with [brushed satin finish] [reflective polished finish] [____].] *** [Extruded aluminum complying with ASTM B221 with [[clear] [bronze] [black] anodized finish.] [fluoropolymer colored paint coating[____].]] *** [Hot rolled solid steel shapes with integral glazing flanges with [electrostatically applied powder paint coating] [____].]
- C. Material minimum thickness: As determined by manufacturer to meet performance requirements specified in Paragraph [1.4] [____].
- D. Size, shape, and configuration: [As indicated on Drawings and approved shop drawings.] [As designed by manufacturer to efficiently frame glass structure and meet design criteria specified in Paragraph [1.4] [____].]
- E. Corner joints: [Coped, mechanically fastened, and sealed to prevent water leakage.] [Mitered, welded, and finished smooth and flush with adjacent surfaces.]
- F. Glazing beads: Cold formed metal applied from interior or exterior, and designed for snap-in installation.



2.4 TENSION TRUSS JOISTS

***** One method of supporting the glass canopy panels is with tension truss joists installed perpendicular to the glass surface. Include this article if tension truss joists are to be used to support glass canopy. *****

A. Support glass canopy panels with tension trusses consisting of:

***** Tension members can be either stainless steel rope (cable) or stainless steel rods. *****

1. Tension members: [Stainless steel wire rope.] [Stainless steel solid rods complying with ASTM A276 with [brushed satin finish.] [reflective polished finish.]] Type, diameter, tensile strength determined by manufacturer to meet design criteria specified in Paragraph [1.4] [_____].
2. Hardware: Provide connectors, turnbuckles, studs, and other hardware as shown on approved shop drawings and as required for fabrication of tension joists.
3. Tubing: Stainless steel complying with ASTM A269 with [brushed satin finish.] [reflective polished finish.]
4. Fittings to join glass panels to tension trusses: Stainless steel complying with ASTM A276 with [brushed satin finish.] [reflective polished finish.]

B. Placement: Truss joists shall be installed [above] [below] and perpendicular to glass canopy panels.

C. Truss configuration, dimensions, spacing, and component sizes: As designed by manufacturer and indicated on shop drawings to efficiently support glass canopy and meet performance criteria specified in Paragraph [1.4] [_____].

2.5 FITTINGS

***** MASA Architectural Canopies, Inc. designs and fabricates a broad range of stainless steel fittings for connecting glass panels together and to other support systems and substrates. It is important that fittings be designed for specific project conditions and loadings and be provided by entity responsible for canopy design. Stresses induced in glass panels by fittings must be compatible with glass strength. MASA Architectural Canopies, Inc. fittings have been independently tested to ensure quality and structural performance. *****

A. Provide structurally engineered and independently tested fittings by an independent laboratory in the United States for connecting glass panels and fins together and for attachment to supporting substrates.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

16

- B. Material: Stainless steel complying with ASTM A276, Type 316 with [brushed satin finish] [reflective polished finish].]
- C. Types: Configuration, number of points, size, and spacing shall be determined by manufacturer and scheduled on shop drawings to accommodate project design and meet performance criteria specified in Paragraph [1.4] [_____]. Ensure that fitting-induced stresses do not exceed glass strength.
- D. Providing fittings with countersunk stainless steel bolts, Delrin bushings, and resilient gaskets.

2.6 ACCESSORIES

- A. Provide glazing accessories, anchors, and fasteners of type recommended by canopy manufacturer and as required for complete, functional, weather tight installation.
- B. Anchorage devices: Clips, anchors, fasteners, and shims required for secure installation of glass canopy. Type, size, and spacing as recommended by canopy manufacturer.
- C. Cleaners and primers: Recommended by manufacturer to be compatible with substrate and glazing materials.
- D. Setting blocks: Neoprene or EPDM complying with ASTM C864.
- E. Edge blocks: Elastomeric material of hardness required to limit lateral movement of glass.
- F. Gaskets: Molded or extruded elastomeric type of profile and hardness required to maintain weather tight seal and complying with ASTM C509, ASTM C864, or ASTM C1115.
- G. Glazing tape: Preformed butyl compound, non-staining, non-migrating in contact with non-porous surfaces, coiled on release paper, complying with ASTM C1281.
- H. Glazing sealant: Chemically curing type complying with ASTM C920, compatible with materials and conditions, and capable of anticipated joint movement without watertight seal failure.
- I. Contact structural sealant: High performance, two component, non-sag, neutral cure, ultraviolet resistant, silicone sealant designed for structural glazing and complying with ASTM C920.



2.7 CANOPY FABRICATION

- A. Insofar as possible, fit and assemble canopy in shop.
- B. Fabricate free of visual distortion and defects. Accurately fit and secure joints and corners. Make joints flush, hairline, and weatherproof.
- C. Prepare components to receive anchor devices. Fabricate anchors.
- D. Arrange fasteners and attachments to ensure concealment from view.
- E. Fabricate to drain water entering joints, condensation, and migrating moisture occurring within unit.

PART 3 - EXECUTION

***** Edit this article to reflect type of glass canopy and components being installed. Delete non-applicable items and requirements. *****

3.1 COORDINATION

- A. Coordinate provision of glass canopy construction of support [columns] [beams] [walls] [framing] [_____] specified in [Section [03 30 00] [03300] - Cast-in-Place Concrete.] [Section [04 05 10] [04800] - Masonry Assemblies.] [Section [05 12 00] [05120] - Structural Steel.] [Section [____].] Ensure that provision is made for attachments and transfer of calculated loads. Provide [sleeves,] [inserts,] [anchor bolts,] [bearing plates] [reglets,] [_____] and other attachment items in sufficient time for installation. Ensure that blockouts, pockets, bearings, [_____] for glass canopy components are provided, accurately placed, and properly sized.
- B. Coordinate provision of glass canopy with flashing specified in Section [07 60 00] [07600] - Flashing and Sheet Metal and Section [07 90 00] [07900] - Joint Protection to ensure that canopy to building connections are waterproof.
- C. Field verify dimensions prior to fabricating glass canopy components.

3.2 INSPECTION

- A. Prior to delivery of glass panels to site, verify that support framing and substrates are ready to receive glass canopy. Verify alignment, dimensions, and tolerances are correct.

SECTION [08 44 29] [08973] [10 5020] Glass Canopies

18



- B. Report unacceptable conditions and deficiencies. Do not proceed with installation until corrective action has been performed.
- C. Inspect glass panels for chipped edges, scratches, abrasions, and other damage.

3.3 GENERAL INSTALLATION

- A. Site assemble and erect glass canopy in accordance with approved shop drawings, manufacturer's installation instructions, and GANA Glazing Manual.
- B. Damaged glass: Do not install glass with edge damage or other imperfections. Remove from site and replace.
- C. Allow for settling, expanding, and contracting to occur without breaking glass.
- D. Do not field cut or alter structural framing without written approval from manufacturer and Architect.

3.4 METAL FRAMING

***** Include this article if glass canopy panels are installed with metal support framing. *****

- A. Use anchorage devices to securely attach metal framing to support structure and to accommodate construction tolerances and irregularities.
- B. Insulate dissimilar metals to prevent electrolysis and other forms of corrosion with bituminous paint or non-absorptive gasket to prevent contact.
- C. Align framing plumb, level, and free of warp or twist.

3.5 GLAZING

- A. Protect adjacent surfaces sealants and glazing materials with masking tape or other means.
- B. Install setting blocks and spacers as recommended by canopy manufacturer and indicated on approved shop drawings.
 - 1. Place setting blocks at quarter points. Maintain [6 inches] [152 mm] space from corners.
 - 2. Set blocks in sealant.



SECTION [08 44 29] [08973] [10 5020] Glass Canopies

- C. Provide edge blocking as required to prevent sideways movement of glass in glazing channel.
- D. Ensure glazing channels and stops provide required bite on glass, minimum edge and face clearances, and adequate sealant thickness.

***** Various glazing methods can be used depending on type of glass canopy. Typical methods are tape glazing, gasket glazing, wet sealant glazing, and structural sealant glazing. Glazing methods can be selected and specified by editing the following options or methods can be determined by glass canopy manufacturer. *****

- E. Glazing methods: [Type as determined by manufacturer and indicated on approved shop drawings.] [Use the following methods for applications indicated on Drawings.]
 - 1. Tape glazing:
 - a. Cut glazing tape to length and set continuously against permanent stops and projecting slightly above sight line.
 - b. Tape joints: Butt joints. Do not overlap tape. Seal joints with compatible sealant.
 - c. Rest glass on setting blocks and push against tape for full contact at perimeter of lite.
 - d. Remove tape release paper immediately prior to placing glass.
 - e. Install compressible gasket against glass and secure with removable glazing stop.
 - f. Knife trim protruding edge of glazing tape.



SECTION [08 44 29] [08973] [10 5020] Glass Canopies

2. Gasket glazing:
 - a. Fabricate two piece compression gaskets to exactly fit openings.
 - b. Install soft compression gasket against permanent stops. Miter cut and bond together corners.
 - c. Rest glass on setting blocks. Insert dense compression gasket to press glass against soft gasket and lock in place against removable stop.
 - d. Apply sealant to gasket joints.
 - e. Install gaskets to protrude slightly beyond glazing stops.
3. Wet sealant glazing:
 - a. Install spacers and sealant backing between glass and stops. Position to control depth and width of sealant.
 - b. Apply sealant to glazing channels without voids. Ensure complete bond of sealant to glass and channel surfaces.
 - c. Tool exposed sealant surfaces to provide wash away from glass.
4. Structural silicone glazing: Use for [butt glass joints.] [adhering panels directly to metal support framing.] [joining glass canopy panels to laminated glass joists.]
 - a. Cleaning: Thoroughly clean all joints and glazing areas immediately prior to sealant application. Remove oil, dust, grease, water, surface dirt, contaminants, and other foreign matter. Vacuum or blow out dust and loose particles from joints. Do not use water cleaning treatments.
 - b. Use primers only as recommended by sealant manufacturer. Field test with and without primer before actual application.
 - c. Mask areas adjacent to joints to insure neat sealant line. Do not allow tape to touch surfaces to which sealant will be applied.
 - d. Install sealant back-up spacers as indicated on Drawings and approved shop drawings.



SECTION [08 44 29] [08973] [10 5020] Glass Canopies

- e. Apply silicone structural sealant in continuous operation. Tool sealant immediate before skin forms. Tool concave to ensure complete contact.
- f. Post application test: After structural sealant has cured 14 to 21 days, conduct field test as prescribed by manufacturer to test sealant adhesion. Replace sealant not passing test.

3.6 MECHANICAL ASSEMBLED GLASS UNITS

***** In addition to tape, gasket, and sealant type glazing, glass canopy panels can be mechanically attached to each other and to supporting structure with stainless fittings. Glass fin joists and tension truss canopies require mechanical connections with fittings. Include this article if glass panels are to be mechanically installed with fittings. *****

- A. Mechanically install glass canopy panels with stainless steel fittings as designed by manufacturer and indicated on approved shop drawings.
- B. Glass joists: Mechanically join glass fin joists to panels with connector fittings to provide stabilization and support.
- C. Tension trusses: Tension truss joists shall be mechanically joined to glass panels to provide structural support.
- D. Glass panels shall be mechanically attached directly to supporting substrate with fittings and anchors.
- E. Secure glass panels to fittings with bolts. Torque bolt to amount specified on approved shop drawings using calibrated tool. Lock torqued bolt into position to prevent backoff. Reset calibrations regularly to ensure accurate torquing.

3.7 CLEANING

- A. Clean excess sealant from glass and other surfaces immediately after application. Use solvents or other cleaners recommended by manufacturer.
- B. Remove protective material from prefinished surfaces.
- C. Wash exposed surfaces using a solution of mild detergent in warm water, applied with soft, clean cloths. Do not use abrasives. Take care to remove dirt from corners. Wipe surfaces clean.

END OF SECTION



SECTION [08 44 29] [08973] [10 5020] Glass Canopies